



DeKalb County
Department of Purchasing and Contracting



Talisa Clark, MBA, CPPO, Interim Chief Procurement Officer

November 14, 2016

TO: All Bidders under Invitation to Bid (ITB) No. 16-100768
FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. 1

Invitation to Bid (ITB) No. 16-100768, DeKalb County Sanitation Administration Building Modifications is hereby amended as follows:

- A. **Modifications to the Bid:** Instructions to Bidders – Time and Liquidated Damages, (page 9) of the ITB documents is changed to: Contractor shall fully complete the Work within forty (40) calendar days from and including the acknowledgement date of the Notice to Proceed.
- B. The following questions were received pertaining to this Invitation to Bid. The questions and the resulting answers appear below:

1. **Question:** It was mentioned in the meeting on Thursday November 3rd that the data/telephone will be ran from the new walls to the data room and left rolled up in the ceiling for the county's contractor to terminate. In the past we have not ran the data/telephone line, but have installed a conduit chase in the wall for the county's contractor to pull from the new data/phone outlet to the termination panels. Will we need to price the full run or just the chase?

Answer: We want the contractor to run the data/telephone cables from the office outlets all the way to the communication room, not just the conduit.

2. **Question:** Can you please provide us the information of the carpet product data and style. We understand the county will provide; however, our subcontractors are requesting this information.

Answer: We did not buy the carpet tiles. They were bought by the general contractor when the building was built in 2008. They had to come and replace the tiles once because of a manufacturing defect and the tiles we have left are from that replacement. The manufacturer was The Mohawk Group and the manufacturer's part number is ST90000103 and these were part of Dyelot C73207. They are 24"x24" in size.

- C. It is the responsibility of each Bidder to ensure that he/she is aware of all addenda issued under this ITB.

ADDENDUM NO. 1

16-100768, DeKalb County Sanitation Administration Building Modifications

Page 2 of 2

- D. Please sign and return this addendum with your bid submittal. You may call Beverly D. Williams, Sr. Procurement Agent, at 404-371-3648 before the bids are due to confirm the number of addenda issued.

All other conditions remain in full force and effect.

Beverly D. Williams

Beverly D. Williams, CPPO, CPPB

Sr. Procurement Agent

Department of Purchasing and Contracting

The acknowledgement must be signed and submitted with the bid.

ACKNOWLEDGMENT

Date: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

(Signature)

(Title)

bdw:ph 