

August 20, 2019


TO: ALL BIDDERS UNDER ITB NO. 19-101066

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. #3

Invitation to Bid (ITB) No. 19-101066 “Steel Roofing System For the Storage Containment Building” is hereby modified as follows:

1. We have received questions pertaining to this ITB. The questions and their resulting answer appear below:
 - A. Does the structure have to be clad in metal and an A framed structure?
Answer: Yes, A frame structure. The structure must be an A frame structure due to the driveways and to allow big trucks to pass through the structure on all openings.
 - B. Would a single sloped structure with TPO membrane for roofing be allowed?



Answer: The single sloped structure will not work due to the height on the lower end. It will possibly block the trucks from passing underneath the structure. The TPO membrane is not acceptable because we believe it will be an ongoing maintenance issue. We prefer to stick with the scope of work and structure clad in metal.

2. All other conditions remain in full force and effect.
3. It is the responsibility of each bidder to ensure that he/she is aware of all addenda issued under this ITB. Please sign and return this addendum.

Kyheem Bristol
Procurement Agent
Department of Purchasing and Contracting

ACKNOWLEDGEMENT

Date

The above Addendum is hereby acknowledged:

(Name of Bidder)

(Signature)

(Title)

KB