

October 11, 2019

TO: All Bidders under **ITB No. 19-101139, Henderson Park Tennis Side Restroom Site Prep**

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. # 3

Invitation to Bid (ITB) No.: 19-101139, Henderson Park Tennis Side Restroom Site Prep, is hereby amended as follows:

1. The Bid Due has been extended until **October 17, 2019 at 3:00 PM EST.**
2. The questions received and their resulting answers pertaining to this Bid appear below:
 - A. **Question:** There is no line item to bid plumbing or gravel building pad, where should these costs be categorized?

Answer: Please see the attached Revised Bid Sheet, Page 18, which includes a line item for these items. Please be reminded that pages 17-21 must be submitted in a separate sealed envelope.

- B. **Question:** Has a building permit been applied for and issued? Since the County is purchasing and installing the building under a separate contract we can't get the building permit. There needs to be a building permit in place in order for us to get utility permits.

Answer: The County will provide Building Permit.

- C. **Question:** Are there any permit fees we should incorporate in the bid?

Answer: Only charges for Utility Permits, if any.

- D. **Question:** Electrical – the drawing show an electrical line connecting to the existing transformer, should we:


A- If the feed is directly from the transformer, Ga Power will typically run the conduit and wire to a meter base on the building because it is a single phase 120/240 connection.

OR

B- There is an empty meter base already wired from the transformer, located near the transformer. Is that to be utilized for the building, in which case we will have to run conduit and wire from that meter base. Which is it?

Answer: Please utilize B use existing meter base at transformer and run conduit.

3. It is the responsibility of each bidder to ensure that he/she is aware of all addenda issued under this ITB. Please sign and return this addendum. You may call Jennifer Schofield, Procurement Agent, 404.687.4042; before the Bids are due to confirm the number of addenda issued.
4. All other conditions remain in full force and effect.


Jennifer Schofield
Procurement Agent
Department of Purchasing and Contracting

ACKNOWLEDGMENT

Invitation to Bid (ITB) No.: 19-101139, Henderson Park Tennis Side Restroom Site Prep

Date: _____

The above Addendum #3 is hereby acknowledged:

(NAME OF FIRM)

(Name and Signature)

(Title)

jjs/DR

REVISED PAGE 18

DeKalb County / City of Tucker				
Henderson Park Restroom Addition				
Item	Qty	Unit	Unit Price	Subtotal
Tree Protection Fence	300	lf		
Silt Fence (Type C)	1,100	lf		
Temporary Seeding	1,700	sy		
Clearing	0.10	ac		
Debris Removal	1	ls		
Grading				
Rough Grading	150	cy		
Fine Grading	3,000	sf		
Pavement				
Concrete -Sidewalk	140	sy		
Electrical Line	300	lf		
Sanitary Sewer - 6" DIP	520	lf		
Waterline - 1" Copper	600	lf		
Permanent Grassing	1,700	sy		
Permitting	1	LS		
Plumbing	1	LS		
Gravel Building Pad	1	LS		
SUBTOTAL				
10% CONTINGENCY				
TOTAL				