

September 24, 2024

TO: ALL BIDDERS UNDER ITB No. 24-101694, NORTH INDIAN CREEK DRIVE TRAFFIC SIGNAL & PAVEMENT MARKING

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. 1

Invitation To Bid (ITB) No. 24-101694, North Indian Creek Drive Traffic Signal & Pavement Marking is hereby amended as follows:

1. We have received questions pertaining to this solicitation. The questions and their resulting answers appear below:

A. Question: Given the proximity to Stone Mountain and the high likelihood of encountering rock while directional drilling or drilling for shafts, would the city consider including a rock adder as a bid item? If not, would the county allow a change order if we encounter rock during the project?

Answer: We have no history of encountering rock in this area. If rock is encountered, we would be willing to consider a change order.

B. Question: I noticed that there are items listed on the Bid Price Form (pages 14-15) that don't appear in the plans. Could you please clarify where we can find the corresponding plans, or if these bid items should be removed?

Bid Item	Description	Quantity	Unit
210-0100	GRADING COMPLETE	1	LS
402-1802	RECYCLED ASPH CONC PATCHING, INCL BITUM MATL & H LIME	1	TN
402-3130	RECYCLED ASPH CONC 12.5 MM SUPERPAVE, GP 2 ONLY, INCL BITUM MATL & H LIME	4	TN
413-0750	TACK COAT	5	GL
432-5010	MILL ASPH CONC PVMT, VARIABLE DEPTH	62	SY
441-0108	CONC SIDEWALK, 8 IN	31	SY

Answer: Most of these items are related to removal of an existing traffic island at the intersection in North Indian Creek Drive. The island is shown on the aerial view on sheet 26-0008. The concrete sidewalk item is for construction of ADA ramps on the east side of the intersection. There are notes on the plan showing the ramp locations and quantities.

Page 2

Addendum No.1


ITB No. 24-101694 – North Indian Creek Drive Traffic Signal & Pavement Marking

- C. **Question:** On Page 4 of the ITB, it's written "All traffic signal equipment, including poles and mast arms, shall have a black finish." Can you confirm whether vehicle detection equipment is also required to be finished in Black?

Answer: The vehicle detection equipment does not need to have a black finish.

2. It is the responsibility of each bidder to ensure that he/she is aware of all addenda issued under this ITB. Please sign and return this addendum with your response. You may email Jenifer Chapital, Procurement Agent, at JChapital@dekalbcountyga.gov or call 404-371-2569 before the Bids are due to confirm the number of addenda issued.

3. All other conditions remain in full force and effect.



Jenifer Chapital, MBA
Procurement Agent

DR/jgc

Page 3

Addendum No. 1

ITB No. 24-101694 – North Indian Creek Drive Traffic Signal & Pavement Marking

ACKNOWLEDGEMENT

Date: _____

The above Addendum #1 is hereby acknowledged:

(NAME OF BIDDER)

(Signature)

(Title)