

September 20, 2019

TO: All Bidders under **RFQ No. 19-3003712, FIRE STATION #19 - PARTIAL REMOVAL AND REPLACEMENT OF CONCRETE DRIVEWAY**

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. # 1

Request for Quotation (RFQ) No.: 19-3003712, FIRE STATION #19 - PARTIAL REMOVAL AND REPLACEMENT OF CONCRETE DRIVEWAY, is hereby amended as follows:

1. The deadline for this RFQ has been extended to **3:00 p.m. EST, Wednesday, September 25, 2019.**
2. We have received questions pertaining to this Request for Quote. The questions and their resulting answers appear below:
 - A. **Question:** What is the specific mix specification for the “5000 PSI 24-hour DOT concrete” to be used in the construction of the concrete apron?
Answer: The concrete needs to be 5000 psi, 24hr DOT with fiber mesh.
 - B. **Question:** Will the concrete require a cylinder testing?
Answer: The concrete does not need to be cylinder tested.
 - C. **Question:** Will the dumpster(s) be allowed to remain on site during job?
Answer: No, there is no space to leave a dumpster onsite.
 - D. **Question:** Does the debris have to be hauled off via dump truck and does it have to be hauled off daily?
Answer: The debris needs to be hauled off daily via dump truck or trailer.
 - E. **Question:** What is the dimension of the underground fuel storage tanks?
Answer: We cannot provide the exact dimension at this time. However, it should be noted that the storage tanks do not extend beyond the existing concrete apron and will not interfere with this work.

F. **Question:** When the asphalt breaks off, can we do a cold patch for the affected areas?

Answer: Yes, if it is a small area.

G. **Question:** Would the drainage be coming out?

Answer: Yes, the drainage would be coming out. The drainage area should be framed out. The County would be responsible for replacing the drainage.

3. The scope of work has been revised. **DELETE** “Attachment A - Scope of Work”, page 3 in its entirety and **REPLACE** with the attached **Revised Scope of Work**.
4. The quote form has been revised to include quote for alternative work. **DELETE** “Attachment B – Quote Form”, page 4 in its entirety and **REPLACE** with the attached **Revised Quote Form**.
5. It is the responsibility of each bidder to ensure that he/she is aware of all addenda issued under this RFQ. Please sign and return this addendum. You may call Lola Awonusi, Procurement Technician, 404.371.6211; before the Quotes are due to confirm the number of addenda issued.
6. All other conditions remain in full force and effect.

Lola Awonusi
Procurement Technician

ACKNOWLEDGMENT

Date: _____

The above Addendum #1 is hereby acknowledged:

(NAME OF BIDDER)

(SIGNATURE) (TITLE)

DR:la

ATTACHMENT A

REVISED SCOPE OF WORK

The Department of Fire Rescue is seeking qualified vendors to perform the following work at Fire Station 19, located at 3253 Mercer University Drive, Atlanta, GA 30341. The work will focus on removing the existing asphalt paving, grading, installing stone as needed, and pouring an 8-inch 5000 PSI 24-hour DOT concrete apron at the rear entrance of the apparatus bay. Estimated area is 4,400 SF.

Installation shall include the following:

- Saw cut asphalt for straight clean edge.
- Tear out old asphalt and remove from site.
- Grade all areas to accommodate an 8-inch concrete pour.
- Fill and pack all areas as needed.
- Dowel rebar into existing slab.
- Provide #5 rebar and sheet wire mesh as needed.
- Remove and replace existing curb on both sides of the drainage. 22 feet and 55 feet of curb are to be removed on both sides, respectively.
- Remove and replace existing 21 feet by 24 inches curb and gutter, by the fuel storage tank area, with 6-inch curb and 18 inches gutter.
- Pour all areas with 5000 PSI 24-hour DOT concrete mix with commercial grade-fiber mesh to a thickness of 8 inches.
- Dowel into existing concrete: The dowels should be from one end of the existing concrete apron to the other end. The dowels should be 24" OC across the apron with rows of rebar 12" OC going from curb to curb. This grid pattern should extend a minimum of 24" out from the edge of the existing concrete apron.
- Trowel and bull float concrete.
- Install expansion tool joints.
- Lite broom finish.
- Clean up work and area and dispose of all debris.

(Continued on next page)

ATTACHMENT A

REVISED SCOPE OF WORK

Additional Information / Requirements:

Fire Station 19 has fuel storage tanks; however, they do not extend beyond the existing concrete apron and will not interfere with this work. Special care should be taken during demolition work. The successful bidder shall be responsible for job site dumpster and removal of all demolition debris. The bidder will need to haul away debris daily. There is no room to leave a dumpster onsite

There will be a non-mandatory pre-bid meeting / site visit to attend on site for any qualified vendors to become familiar with local conditions, which may affect the work to be performed, the equipment, materials, and labor required. No additional allowances shall be made due to the lack of knowledge of the conditions at the site.

Alternate Quote:

Mill and blacktop the proposed area with asphalt, in place of concrete.

ATTACHMENT B

REVISED QUOTE FORM

DeKalb County, Georgia is requesting a quotation for the following:

Request for Quotation No. 19-3003712

FIRE STATION #19 - PARTIAL REMOVAL AND REPLACEMENT OF CONCRETE DRIVEWAY

BASE BID:

The responder declares that he has carefully examined, RFQ # 19-3003712, Fire Station #19 - Partial Removal and Replacement of Concrete Driveway, the Scope of Work contained, and that he proposes and agrees, that if his quote is accepted, to provide the necessary services and furnish all material and labor specified in this RFQ, or necessary to complete the work in the manner therein specified within the time specified, , as therein set forth for the following lump sum amount which sum is hereinafter referred to as "Lump Sum."

LUMP SUM TOTAL \$ _____ \$ _____
(State amount in writing on this line) (In Figures)

(Continued on next page)

ATTACHMENT B

REVISED QUOTE FORM

ALTERNATE QUOTE:

A Lump Sum price is to be provided, to mill and blacktop the proposed area with asphalt, in place of concrete.

Alternates to the base bid:

The responder declares that he has carefully examined, RFQ # 19-3003712, Fire Station #19 - Partial Removal and Replacement of Concrete Driveway, the Scope of Work contained, and that he proposes and agrees, that if his quote is accepted, to provide the necessary services and furnish all material and labor specified in this RFQ, or necessary to complete the work in the manner therein specified within the time specified, , as therein set forth for the following lump sum amount which sum is hereinafter referred to as "Lump Sum."

LUMP SUM TOTAL \$ _____ \$ _____
(State amount in writing on this line) (In Figures)