

September 23, 2019

**TO:** All Bidders under **RFQ No. 19-3003712, FIRE STATION #19 - PARTIAL REMOVAL AND REPLACEMENT OF CONCRETE DRIVEWAY**

**FROM:** Department of Purchasing and Contracting, DeKalb County, Georgia

**ADDENDUM NO. # 2**

**Request for Quotation (RFQ) No.: 19-3003712, FIRE STATION #19 - PARTIAL REMOVAL AND REPLACEMENT OF CONCRETE DRIVEWAY**, is hereby amended as follows:

1. The depth of milling and thickness of the blacktop, for the alternate quote, is clarified to be 10-12" of GAB (Graded Aggregate Base) and a minimum of 4" layer of asphalt. The milling is to remove the existing layer of asphalt. Once the existing asphalt is removed, the bidder will need to remove the existing base to proper depth so that a new base of GAB can be placed and compacted.
2. It is the responsibility of each bidder to ensure that he/she is aware of all addenda issued under this RFQ. Please sign and return this addendum. You may call Lola Awonusi, Procurement Technician, 404.371.6211; before the Quotes are due to confirm the number of addenda issued.
3. All other conditions remain in full force and effect.

---

Lola Awonusi  
Procurement Technician

**ACKNOWLEDGMENT**

Date: \_\_\_\_\_

The above Addendum #2 is hereby acknowledged:

\_\_\_\_\_  
(NAME OF BIDDER)

\_\_\_\_\_  
(SIGNATURE)

\_\_\_\_\_  
(TITLE)

*DR:la*