

DEKALB COUNTY

DEPARTMENT OF WATERSHED MANAGEMENT 4572 MEMORIAL DRIVE DECATUR, GEORGIA 30032

(404) 687-4075

DEKALBBACKFLOW@DEKALBCOUNTYGA.GOV

 ${\tt BACKFLOW} \, \overline{{\tt PREVENTION}} \, {\tt ASSEMBLY} \, \overline{{\tt TEST}} \, \& \, {\tt MAINTENANCE} \, \overline{{\tt REPORT}}$

	(PLEASE PRINT)									
Account	Contact Name:				Motor #	Phone #	Meter Peading:			
							Meter Reading:			
	Mailing Address:Service Address:				City		ST: Zip:			
	Service Address				City		31	zip		
	Assembly Test Results: Pass Fail Assembly Serial No									
Assembly	Make:	A Model:	Assembly Serial No			 Sizo:				
			Model: Size: CDA □ DETECTOR CHECK (BYPASS) PVB							
	Type: □ RPP □ DC □ DCDA □ DETECTOR CHECK (BYPASS) PVB □ RPDA Date Installed: Location on property:									
	□ New		Orientation Use				Protection			
	□ Existing				□ Vertical Up □ Dome					
4	Previous Assembly Serial No:									
	•					izontal				
ce	Initial Test Results				Repairs/Comments			Re-Tes	t Results	
		Tightness	Differential					Tightness	Differential	
	Check Valve #1 (RPP,	☐ Leak						☐ Leak		
nar	DC, Other:)							☐ Tight		
nte	Check Valve #2 (RPP,							☐ Leak		
۸ai	DC) Relief Valve (RPP)	☐ Tight						☐ Tight		
8 8	Buffer (RPP)	_						_		
Testing & Maintenance		_								
	Shutoff Valve #1									
	Shutoff Valve #2	☐ Leak	☐ Tight							
	Air Inlet Valve	☐ Leak	☐ Tight					Re-Test		
	Check Valve	Open at	PSID					Open atPSID		
	Line Pressure	Held at	PSID					Held atPSID		
	Alarm Campany/F	iro Donort	mant Natific							
Notification	Alarm Company/Fire Department Notified: Notified By:									
	Turn Off Date/Time:				Turn On Date/Time					
S S	Turn Off Date/Time:Turn On Date/Time:									
+	Test Kit Make:				Certificate Expiration Date:					
TestKit					Last Calibration Date:					
Ţ	East calibration bate.									
	Tester Name: Telephone No									
Tester	Tester Certification: Certificate Expiration Date:									
	Tester certifies that this assembly has been tested with the above listed procedure and verifies that isolation									
	valves were returned to pre-test orientation. Test Procedure:									
	Signature: DATE:									