

August 20, 2020

TO: All Bidders under Invitation to Bid No. 19-101146

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. 5

Invitation to Bid (ITB) No. 19-101146, *Construction of Fire Station No. 7*, is hereby amended as follows:

1. The bid due date has been extended to **August 26, 2020, 3:00 P.M. EST.**
2. The answers to Questions 21, 26, 31, and 37 from Addendum No. 4 have been revised and are provided below. Bidders shall utilize these revised responses to complete their bids.

21.	Question:	<i>“MEP-01, Specs – There are no sections in the specifications for lighting control systems or low voltage/fire alarm wiring. Is the fire alarm required to be in conduit for entire building?”</i>
	Answer:	All lighting control systems and low voltage/fire alarm wiring shall be installed in conduit for the entire building.
26.	Question:	<i>“Are the openings inside the apparatus bay to be considered interior or exterior?”</i>
	Answer:	They should be <u>exterior</u> doors that go through the rated wall between the living quarters and engine bay.
31.	Question:	<i>“There are no sections in the specifications for lighting control systems or low voltage/fire alarm wiring. Is the fire alarm required to be in conduit for the entire building?”</i>
	Answer:	See the response to Question #21.
37.	Question:	<i>“There are no sections in the specifications for lighting control systems or low voltage/fire alarm wiring. Is the fire alarm required to be in conduit for entire building?”</i>
	Answer:	See the response to Question #21.

3. The answer to the following request for product substitution from Addendum No. 4 has been revised below and shall be utilized for completion of bids:

3.	Question:	<p><i>Product Substitution Request:</i></p> <p><i>Jewers Four Fold Doors</i></p>
	Answer:	<p>This product is not approved for use at this time. Bidders shall review the revised specification section “08365 Four Fold Door Systems” below and coordinate with revised drawings provided in Addendum No. 2.</p> <p>3. Apparatus Bay Doors- clarifications added to section (8365).</p> <ul style="list-style-type: none"> a. 2.3 Item G. Vision Panels- Add 1 inch “tempered” vision panels. b. 2.4 Operator Item D electric controls- Add Control panel assemblies shall be UL listed as per NFPA 70. c. Add a quality assurance section to include the doors shall be designed to withstand external or internal horizontal wind loads of 25 pounds minimum per square foot. d. Drawings reflect interior opening bi fold doors. Please ensure contractors are clear the doors are interior opening and not exterior opening. e. Drawings reflect squared glass in the vision panels. The top row glass of the apparatus bay door glass should match the building door opening arch or radius. This will require arched glass rather than squared glass.

4. It is the responsibility of each bidder to ensure that he or she is aware of all addenda issued under this ITB. Please sign and return this addendum. You may email Crystal Creekmore, Senior Procurement Agent, at ccreekmore@dekalbcountyga.gov before the bids are due to confirm the number of addenda issued.
5. All other conditions remain in full force and effect.



Crystal Creekmore, MBA, CPPB
Senior Procurement Agent
Department of Purchasing and Contracting

ACKNOWLEDGEMENT

Date: _____

Addendum No. 5 is hereby acknowledged:

(Company Name)

(Printed Name of Bidder's Authorized Signer)

(Signature of Bidder's Authorized Signer)

(Title)