

| Date | Oprn | CHATTAH OOCHEE RIVER 044- 1290-03 | Water Usage | | Raw Water Quality | | | | | | | Plant Operation | | | Combined Filtered Water Quality | | | | | |
|--------|---------|--|---|--|-------------------|----------------------|--------------------|-----------|-----------|-------------------------------|-------------------------------|--|--|---|------------------------------------|-------------------------------|-------------------------------|-------------------------------|--|---|
| | | | Processed or Treated thru Plant (MG) | Treated Water Pumped to Dist. System (MG) | pH | Alkalinity (mg/L) | Temp (degree C) | Fe (mg/L) | Mn (mg/L) | Maximum Turbidity (NTU) | Minimum Turbidity (NTU) | Total Hours Plant Operated (hrs) | Number of Filters Actually in Use | Maximum Settled Water Turbidity (NTU) | pH | Maximum Turbidity (NTU) | Minimum Turbidity (NTU) | Average Turbidity (NTU) | Total Number of Turbidity Measurem ents Performed | Maximum Filtered Particles (in 3 - 15 micron range) (particles/1 00ml) |
| 01 | In Oprn | 77.03 | 69.60 | 59.44 | 6.80 | 20.00 | 17.00 | 0.07 | 0.00 | 1.69 | 1.37 | 24.00 | 10.00 | 0.23 | 6.36 | 0.07 | 0.03 | 0.05 | 48.00 | 18.00 |
| 02 | In Oprn | 79.64 | 69.48 | 56.97 | 6.86 | 21.00 | 17.00 | 0.07 | 0.00 | 2.00 | 1.17 | 24.00 | 10.00 | 0.16 | 6.38 | 0.06 | 0.04 | 0.05 | 48.00 | 31.00 |
| 03 | In Oprn | 74.42 | 65.92 | 58.59 | 6.86 | 21.00 | 16.00 | 0.04 | 0.00 | 1.51 | 1.19 | 24.00 | 10.00 | 0.17 | 6.38 | 0.07 | 0.04 | 0.05 | 48.00 | 10.00 |
| 04 | In Oprn | 75.37 | 70.28 | 60.44 | 6.80 | 22.00 | 17.00 | 0.05 | 0.00 | 1.98 | 0.99 | 24.00 | 10.00 | 0.37 | 6.32 | 0.08 | 0.04 | 0.05 | 48.00 | 17.00 |
| 05 | In Oprn | 43.54 | 71.36 | 63.05 | 6.82 | 22.00 | 15.00 | 0.07 | 0.00 | 6.76 | 1.75 | 24.00 | 10.00 | 0.30 | 6.34 | 0.09 | 0.04 | 0.06 | 48.00 | 15.00 |
| 06 | In Oprn | 74.89 | 68.95 | 60.81 | 6.81 | 22.00 | 15.00 | 0.11 | 0.00 | 6.50 | 5.30 | 24.00 | 10.00 | 0.40 | 6.34 | 0.09 | 0.06 | 0.07 | 48.00 | 40.00 |
| 07 | In Oprn | 74.55 | 68.16 | 58.94 | 6.73 | 23.00 | 16.00 | 0.11 | 0.00 | 10.70 | 4.77 | 24.00 | 10.00 | 11.70 | 6.30 | 0.12 | 0.06 | 0.07 | 48.00 | 437.00 |
| 08 | In Oprn | 75.03 | 70.64 | 58.80 | 6.74 | 22.00 | 17.00 | 0.13 | 0.00 | 7.28 | 4.03 | 24.00 | 10.00 | 0.32 | 6.29 | 0.14 | 0.06 | 0.07 | 48.00 | 15.00 |
| 09 | In Oprn | 73.5 | 70.14 | 61.09 | 6.71 | 21.00 | 17.00 | 0.11 | 0.00 | 7.80 | 6.98 | 24.00 | 10.00 | 0.62 | 6.30 | 0.11 | 0.06 | 0.07 | 48.00 | 11.00 |
| 10 | In Oprn | 80.16 | 70.22 | 59.12 | 6.68 | 22.00 | 19.00 | 0.11 | 0.00 | 8.15 | 6.08 | 24.00 | 10.00 | 0.32 | 6.23 | 0.10 | 0.05 | 0.07 | 48.00 | 10.00 |
| 11 | In Oprn | 79.64 | 67.69 | 59.44 | 6.67 | 20.00 | 18.00 | 0.10 | 0.00 | 6.81 | 6.00 | 24.00 | 10.00 | 0.34 | 6.23 | 0.10 | 0.05 | 0.07 | 48.00 | 16.00 |
| 12 | In Oprn | 79.46 | 72.10 | 58.92 | 6.66 | 19.00 | 19.00 | 0.10 | 0.00 | 6.82 | 6.15 | 24.00 | 10.00 | 0.35 | 6.18 | 0.08 | 0.05 | 0.06 | 48.00 | 28.00 |
| 13 | In Oprn | 79.67 | 70.09 | 57.35 | 6.66 | 21.00 | 20.00 | 0.09 | 0.00 | 7.03 | 5.89 | 24.00 | 10.00 | 0.42 | 6.23 | 0.08 | 0.05 | 0.06 | 48.00 | 13.00 |
| 14 | In Oprn | 75.03 | 69.96 | 57.30 | 6.59 | 20.00 | 20.00 | 0.10 | 0.00 | 6.37 | 4.84 | 24.00 | 10.00 | 0.41 | 6.21 | 0.08 | 0.06 | 0.07 | 48.00 | 17.00 |
| 15 | In Oprn | 74.99 | 68.81 | 58.88 | 6.65 | 20.00 | 20.00 | 0.11 | 0.00 | 8.00 | 5.70 | 24.00 | 10.00 | 0.26 | 6.21 | 0.09 | 0.05 | 0.07 | 48.00 | 14.00 |
| 16 | In Oprn | 71.7 | 68.62 | 57.54 | 6.68 | 19.00 | 16.00 | 0.11 | 0.00 | 8.55 | 5.15 | 24.00 | 10.00 | 0.37 | 6.18 | 0.08 | 0.05 | 0.06 | 48.00 | 14.00 |
| 17 | In Oprn | 67.47 | 64.05 | 57.64 | 6.67 | 21.00 | 16.00 | 0.11 | 0.00 | 5.69 | 4.86 | 24.00 | 10.00 | 0.48 | 6.18 | 0.08 | 0.05 | 0.05 | 48.00 | 11.00 |
| 18 | In Oprn | 69.16 | 67.86 | 58.57 | 6.71 | 21.00 | 17.00 | 0.10 | 0.00 | 4.96 | 4.30 | 24.00 | 10.00 | 0.68 | 6.16 | 0.08 | 0.04 | 0.05 | 48.00 | 23.00 |
| 19 | In Oprn | 60.09 | 68.50 | 59.16 | 6.65 | 22.00 | 16.00 | 0.09 | 0.00 | 4.60 | 3.41 | 24.00 | 10.00 | 0.28 | 6.13 | 0.08 | 0.05 | 0.06 | 48.00 | 24.00 |
| 20 | In Oprn | 68.97 | 72.21 | 61.04 | 6.62 | 21.00 | 18.00 | 0.13 | 0.00 | 11.50 | 2.44 | 24.00 | 10.00 | 0.48 | 6.14 | 0.08 | 0.04 | 0.06 | 48.00 | 24.00 |
| 21 | In Oprn | 70.03 | 68.55 | 58.21 | 6.74 | 21.00 | 17.00 | 0.10 | 0.00 | 4.25 | 3.14 | 24.00 | 10.00 | 0.96 | 6.22 | 0.07 | 0.04 | 0.05 | 48.00 | 143.00 |
| 22 | In Oprn | 65.55 | 65.88 | 58.97 | 6.70 | 22.00 | 18.00 | 0.09 | 0.00 | 3.40 | 2.65 | 24.00 | 10.00 | 0.70 | 6.20 | 0.07 | 0.04 | 0.06 | 48.00 | 27.00 |
| 23 | In Oprn | 67.75 | 67.57 | 60.03 | 6.67 | 19.00 | 18.00 | 0.08 | 0.00 | 2.64 | 2.27 | 24.00 | 10.00 | 0.81 | 6.21 | 0.07 | 0.04 | 0.06 | 48.00 | 14.00 |
| 24 | In Oprn | 63.42 | 78.80 | 64.85 | 6.67 | 20.00 | 19.00 | 0.06 | 0.00 | 2.27 | 2.06 | 24.00 | 10.00 | 0.97 | 6.19 | 0.08 | 0.04 | 0.06 | 48.00 | 23.00 |
| 25 | In Oprn | 64.54 | 72.69 | 64.68 | 6.66 | 21.00 | 19.00 | 0.07 | 0.00 | 3.56 | 1.60 | 24.00 | 10.00 | 0.42 | 6.19 | 0.07 | 0.04 | 0.05 | 48.00 | 14.00 |
| 26 | In Oprn | 63.9 | 75.35 | 61.92 | 6.63 | 21.00 | 19.00 | 0.04 | 0.00 | 1.70 | 1.19 | 24.00 | 10.00 | 0.23 | 6.17 | 0.08 | 0.04 | 0.05 | 48.00 | 37.00 |
| 27 | In Oprn | 67.88 | 70.41 | 59.60 | 6.68 | 23.00 | 19.00 | 0.05 | 0.00 | 1.64 | 1.15 | 24.00 | 10.00 | 0.23 | 6.21 | 0.07 | 0.04 | 0.05 | 48.00 | 12.00 |
| 28 | In Oprn | 67.74 | 68.67 | 57.28 | 6.75 | 21.00 | 16.00 | 0.09 | 0.00 | 2.42 | 1.39 | 24.00 | 10.00 | 0.22 | 6.16 | 0.08 | 0.04 | 0.05 | 48.00 | 11.00 |
| Total | | 1985.12 | 1952.56 | 1668.63 | 187.87 | 588.00 | 491.00 | 2.49 | 0.00 | 146.58 | 97.82 | | | 23.20 | 174.64 | 2.35 | 1.29 | 1.65 | 1344.00 | 1069.00 |
| # Days | | 28 | 28 | 28 | 28 | 28 | 28 | 28 | 28 | 28 | 28 | 28 | | 28 | 28 | 28 | 28 | 28 | 28 | 28 |
| Avg | | 70.90 | 69.73 | 59.59 | | | | | | | | | | 0.83 | 6.24 | | | 0.06 | 48.00 | 38.18 |
| Max | | 80.16 | 78.80 | 64.85 | 6.86 | 23.00 | 20.00 | 0.13 | 0 | 11.50 | | | | 11.70 | 6.38 | 0.14 | | | | 437.00 |
| Min | | 43.54 | 64.05 | 56.97 | 6.59 | 19.00 | 15.00 | 0.04 | 0.00 | | 0.99 | | | 0.16 | 6.13 | | 0.03 | | | 10.00 |

| Date | Oprn | Parameters At Entry Point To Distribution System | | | | | | | | | | | Comments | |
|--------|---------|--|-----------|-----------------|-----------|-----------|--|--------------------------------|--|------------------------------|---------------------------------------|--------------------------|----------|--|
| | | Fe (mg/L) | Mn (mg/L) | Fluoride (mg/L) | pH (Max.) | pH (Min.) | Chlorine Minimum Free Available (mg/L) | Chlorite (mg/L) [if ClO2 used] | Chlorine Dioxide (mg/L) [if ClO2 used] | Peak Hourly Flow (PHF) (MGD) | Chlorine Free Available at PHF (mg/L) | Giardia log Inactivation | | Virus log Inactivation [if ozone or chloramine used] |
| 01 | In Oprn | 0.01 | 0.01 | 0.94 | 9.25 | 8.97 | 1.53 | | | 78.00 | 1.62 | 3.72 | 31.66 | |
| 02 | In Oprn | 0.00 | 0.00 | 0.87 | 9.35 | 9.04 | 1.32 | | | 79.00 | 1.66 | 3.73 | 41.06 | |
| 03 | In Oprn | 0.00 | 0.00 | 0.87 | 9.22 | 9.02 | 1.33 | | | 77.00 | 1.40 | 3.64 | 51.49 | |
| 04 | In Oprn | 0.00 | 0.00 | 0.82 | 9.25 | 9.05 | 1.29 | | | 78.00 | 1.58 | 3.70 | 39.58 | |
| 05 | In Oprn | 0.00 | 0.00 | 0.83 | 9.31 | 9.08 | 1.29 | | | 78.00 | 1.56 | 3.69 | 39.08 | |
| 06 | In Oprn | 0.00 | 0.00 | 0.88 | 9.30 | 9.09 | 1.35 | | | 76.00 | 1.51 | 3.73 | 40.40 | |
| 07 | In Oprn | 0.00 | 0.00 | 0.88 | 9.20 | 8.85 | 1.23 | | | 73.20 | 1.44 | 3.73 | 40.00 | |
| 08 | In Oprn | 0.01 | 0.00 | 0.86 | 9.02 | 8.74 | 1.24 | | | 73.20 | 1.40 | 3.65 | 85.71 | |
| 09 | In Oprn | 0.01 | 0.00 | 0.83 | 9.12 | 8.85 | 1.32 | | | 74.88 | 1.37 | 3.57 | 78.66 | |
| 10 | In Oprn | 0.00 | 0.00 | 0.81 | 9.21 | 9.02 | 1.39 | | | 75.60 | 1.41 | 4.10 | 52.30 | |
| 11 | In Oprn | 0.00 | 0.00 | 0.82 | 9.12 | 8.90 | 1.37 | | | 75.60 | 1.46 | 3.66 | 52.66 | |
| 12 | In Oprn | 0.00 | 0.00 | 0.92 | 9.01 | 8.83 | 1.05 | | | 74.00 | 1.54 | 4.42 | 104.23 | |
| 13 | In Oprn | 0.01 | 0.00 | 0.83 | 9.28 | 8.96 | 1.46 | | | 75.00 | 1.54 | 4.32 | 49.73 | |
| 14 | In Oprn | 0.01 | 0.00 | 0.85 | 9.18 | 8.89 | 1.19 | | | 79.00 | 1.53 | 4.29 | 63.28 | |
| 15 | In Oprn | 0.01 | 0.00 | 0.86 | 9.06 | 8.84 | 1.42 | | | 77.00 | 1.55 | 4.28 | 104.04 | |
| 16 | In Oprn | 0.01 | 0.00 | 0.86 | 9.06 | 8.82 | 1.51 | | | 72.00 | 1.66 | 4.52 | 110.96 | |
| 17 | In Oprn | 0.00 | 0.00 | 0.83 | 9.17 | 8.97 | 1.47 | | | 76.00 | 1.55 | 4.38 | 66.63 | |
| 18 | In Oprn | 0.00 | 0.00 | 0.89 | 9.04 | 8.90 | 1.40 | | | 76.00 | 1.58 | 4.34 | 100.05 | |
| 19 | In Oprn | 0.01 | 0.00 | 0.85 | 9.16 | 8.95 | 1.13 | | | 80.00 | 1.25 | 4.01 | 54.83 | |
| 20 | In Oprn | 0.00 | 0.00 | 0.84 | 9.18 | 8.97 | 1.21 | | | 78.00 | 1.64 | 4.42 | 63.96 | |
| 21 | In Oprn | 0.01 | 0.00 | 0.85 | 9.18 | 9.03 | 1.50 | | | 78.00 | 1.60 | 4.44 | 64.83 | |
| 22 | In Oprn | 0.01 | 0.00 | 0.87 | 9.18 | 9.03 | 1.21 | | | 77.00 | 1.54 | 4.27 | 48.44 | |
| 23 | In Oprn | 0.01 | 0.00 | 0.83 | 9.22 | 9.10 | 1.38 | | | 76.00 | 1.63 | 4.23 | 44.42 | |
| 24 | In Oprn | 0.00 | 0.00 | 0.84 | 9.13 | 8.62 | 1.32 | | | 78.00 | 1.45 | 4.17 | 96.08 | |
| 25 | In Oprn | 0.01 | 0.00 | 0.82 | 9.10 | 8.91 | 1.37 | | | 83.00 | 1.53 | 4.13 | 57.87 | |
| 26 | In Oprn | 0.01 | 0.00 | 0.87 | 9.37 | 9.06 | 1.28 | | | 79.00 | 1.70 | 4.29 | 50.00 | |
| 27 | In Oprn | 0.01 | 0.00 | 0.86 | 9.31 | 9.05 | 1.26 | | | 76.32 | 1.40 | 4.21 | 43.04 | |
| 28 | In Oprn | 0.02 | 0.00 | 0.90 | 9.31 | 9.14 | 1.30 | | | 75.84 | 1.36 | 4.14 | 29.36 | |
| Total | | 0.16 | 0.01 | 23.98 | 257.29 | 250.68 | 37.12 | 0 | 0 | | | | | |
| # Days | | 28 | 28 | 28 | 28 | 28 | 28 | 0 | 0 | | | | | |
| Avg | | 0.01 | 0.00 | 0.86 | | | 1.33 | 0 | 0 | | | 4.06 | 60.87 | |
| Max | | 0.02 | 0.01 | 0.94 | 9.37 | | 1.53 | 0 | 0 | 83.00 | 1.70 | 4.52 | 110.96 | |
| Min | | 0.00 | 0.00 | 0.81 | | 8.62 | 1.05 | | | 72.00 | 1.25 | 3.57 | 29.36 | |

| | | | | | | | | |
|--------------------------|---------------|-----------------|-----------|---------------------------|-----------------------|------------------|-----|-----------------|
| Water System Name | DEKALB COUNTY | WSID No. | GA0890001 | Treatment Facility | DEKALB CO WATER PLANT | Plant No. | 201 | Feb 2018 |
|--------------------------|---------------|-----------------|-----------|---------------------------|-----------------------|------------------|-----|-----------------|

Monthly Surface Water Treatment Operation Report for Turbidity

I - COMBINED FILTERED WATER MONITORING & REPORTING

| | | |
|-----|--|---------|
| (a) | Total number of filtered water turbidity measurements performed: | 1344.00 |
| (b) | Total number of filtered water turbidity measurements < 0.3 NTU: | 1344.00 |
| (c) | Percentage of the turbidity measurements < 0.3 NTU (b/a x 100): | 100.00% |
| (d) | Is the percentage in (c) < 95% | No |
| | [[If Yes, report the date (mm/dd/yyyy) when public notice was issued] | |
| | [[If Yes, report the date (mm/dd/yyyy) when EPD was notified] | |
| (e) | Did filtered water turbidity exceed 1 NTU at any time during the month | No |
| | [[If Yes, report the date (mm/dd/yyyy) when public notice was issued] | |
| | [[If Yes, report the date (mm/dd/yyyy) when EPD was notified] | |

II - INDIVIDUAL FILTER MONITORING & REPORTING

| | | |
|-----|--|-----|
| (a) | Was each filter continuously monitored for turbidity? | Yes |
| (b) | Were the individual filter turbidity monitoring results recorded every 15 minutes? | Yes |
| (c) | Was there a failure of the continuous turbidity monitoring equipment? | No |
| | [[If Yes, perform "Follow-up Actions" 1, 2 and 3] | |
| (d) | Was any individual filter turbidity level > 1.0 NTU in two consecutive measurements? | No |
| | [[If Yes, perform "Follow-up Actions" 1, 2 and 3] | |
| (e) | Was any individual filter turbidity level > 0.5 NTU in two consecutive measurements at the end of 4 hrs of | No |
| | [[If Yes, perform "Follow-up Actions" 1, 2 and 3] | |
| (f) | Was any individual filter turbidity level > 1.0 NTU in two consecutive measurements in each 3 consecutive | No |
| | [[If Yes, perform "Follow-up Actions" 1, 2, 3 and 4] | |
| (g) | Was any individual filter turbidity level > 2.0 NTU in two consecutive measurements in 2 consecutive | No |
| | [[If Yes, perform "Follow-up Action" 5] | |

Comments:

"FOLLOW-UP ACTIONS" to PERFORM

| | |
|---|--|
| 1 | Report, filter number(s); turbidity measurements; and, date(s) the exceedance(s) have occurred. |
| 2 | Produce a "Filter Profile" within 7 days of the exceedance (if there is no obvious reason for exceedance). |
| 3 | Report that "Filter Profile" has been produced and is available for EPD inspection or identify and report, in writing, obvious reason for exceedance. |
| 4 | Conduct a "Self-Assessment" of the filter within 14 days of the exceedance and report that "self-assessment" has been completed and the findings are available for EPD inspection. |
| 5 | Contact EPD no later than 30 days following exceedance, and arrange for a Comprehensive Performance Evaluation (CPE) of your system. |

| | | | | | |
|------------------------------|--------------|-----------------------------------|------------|--------------|------------|
| Entered / Updated by: | Vernon Grant | Certification No. / Class: | 14707 / W1 | Date: | 03/08/2018 |
|------------------------------|--------------|-----------------------------------|------------|--------------|------------|

| | | | | | | | | |
|--------------------------|---------------|-----------------|-----------|---------------------------|-----------------------|------------------|-----|-----------------|
| Water System Name | DEKALB COUNTY | WSID No. | GA0890001 | Treatment Facility | DEKALB CO WATER PLANT | Plant No. | 201 | Feb 2018 |
|--------------------------|---------------|-----------------|-----------|---------------------------|-----------------------|------------------|-----|-----------------|

**Monthly Disinfectant and/or Oxidant Monitoring at the Entry Point and in the Distribution System
(Reporting for Systems using Chlorine - Part 1)**

I - ENTRY POINT Monitoring and Reporting for Public Water Systems using CHLORINE

| | | |
|-----|---|----|
| (a) | At any time during the month, did the residual disinfectant concentration of water leaving the plant (entry point to distribution system) ever fall below 0.2 mg/L? | No |
| | [If Yes, did it last more than 4.0 consecutive hours?] | |
| | [If Yes, report the date when public notice was given to customers] | |
| | [If Yes, report the date when public notice was given to EPD] | |
| (b) | Were there any periods when the plant failed to meet the CT requirements for more than four (4.0) consecutive hours? | No |

II - DISTRIBUTION SYSTEM Monitoring and Reporting for Public Water Systems using CHLORINE

| | | |
|-----|--|------------------|
| (c) | Total number of residual disinfectant measurements performed in the distribution system (This must be equal to or greater than the number of coliform samples required per month): | 246.00 |
| (d) | Maximum residual disinfectant level measured in the distribution system: | 1.76 mg/L |
| (e) | Lowest or minimum residual disinfectant level measured in the distribution system: | 0.10 mg/L |
| (f) | Monthly arithmetic average of all the measurements performed in the distribution system: | 1.25 mg/L |
| (g) | Total number of samples measured without a detectable disinfectant residual: | 0.00 |
| (h) | Percentage of samples without a detectable disinfectant residual (g/c x 100): | 0.00% |
| (i) | Were more than 5% of the residuals in the distribution system undetectable for two (2) months in a row? | No |
| (j) | Was chlorination equipment out of service for more than five (5) working days? | No |

Comments: HPC < 500 cfu/mL for lowest residual sample.

| | | | | | |
|------------------------------|--------------|-----------------------------------|------------|--------------|------------|
| Entered / Updated by: | Vernon Grant | Certification No. / Class: | 14707 / W1 | Date: | 03/06/2018 |
|------------------------------|--------------|-----------------------------------|------------|--------------|------------|

| | | | | | | | | | | |
|---|--|-------------------|-----------|-----------------------------------|-----------------------|--|------------------|-------------------|-----------------|------------|
| Water System Name | DEKALB COUNTY | WSID No. | GA0890001 | Treatment Facility | DEKALB CO WATER PLANT | | Plant No. | 201 | Feb 2018 | |
| Monthly Disinfectant and/or Oxidant Monitoring at the Entry Point (Additional Bromate Monitoring and Reporting for Systems using Ozone - Part 4) | | | | | | | | | | |
| (a) | Did you collect a "bromate" sample at the entry point this month? | | | | | | | | Yes | |
| (b) | List sampling date, laboratory certification number and result of "bromate" sample taken: Laboratory Certification Number | | | | | | | | 929 | |
| Current Period | | | | | | | | | | |
| | Jan/16/2018 | 0.0000 mg/L | | | | | | | | |
| | Feb/20/2018 | 0.0000 mg/L | | | | | | | | |
| | Mar/_/2018 | mg/L | | | | | | | | |
| 1st Period | | 2nd Period | | | 3rd Period | | | 4th Period | | |
| | Jan/18/2017 | 0.0000mg/L | | Apr/18/2017 | 0.0000mg/L | | Jul/19/2017 | 0.0000mg/L | | |
| | Feb/15/2017 | 0.0000mg/L | | May/17/2017 | 0.0000mg/L | | Aug/16/2017 | 0.0000mg/L | | |
| | Mar/15/2017 | 0.0000mg/L | | Jun/14/2017 | 0.0000mg/L | | Sep/20/2017 | 0.0000mg/L | | |
| | Average | | mg/L | | Average | | mg/L | | Average | |
| | | | | | | | | | | |
| [NOTE: If average of samples collected in any consecutive 4-Quarter period exceeds the MCL of 0.010 mg/L, Public Notification is required.] | | | | | | | | | | |
| (c) | Is the average of consecutive 4 quarter period > 0.010 mg/L? If Yes, send copies of the Public Notification (PN) and PN Certification Form and explain the corrective measures taken to prevent reoccurrence of the violation(s). | | | | | | | | No | |
| Comments: | | | | | | | | | | |
| | | | | | | | | | | |
| Entered / Updated by: | | Vernon Grant | | Certification No. / Class: | | | 14707 / W1 | | Date: | 03/08/2018 |

| | | | | | | | | |
|--------------------------|---------------|-----------------|-----------|---------------------------|-----------------------|------------------|-----|-----------------|
| Water System Name | DEKALB COUNTY | WSID No. | GA0890001 | Treatment Facility | DEKALB CO WATER PLANT | Plant No. | 201 | Feb 2018 |
|--------------------------|---------------|-----------------|-----------|---------------------------|-----------------------|------------------|-----|-----------------|

Monthly TOC Removal / SUVA Report Summary

I. TOC Removal Summary

| | | |
|-----|--------------------------------|------------|
| (a) | Date (mm/dd/yyyy) | 02/26/2018 |
| (b) | Source Water Alkalinity (mg/L) | 21.00 |
| (c) | Source Water TOC (mg/L) | 1.70 |
| (d) | Treated Water TOC (mg/L) | 1.00 |
| (e) | Actual TOC Removed (%) | 41.18 |
| (f) | Required TOC Removal (%) | 35.00 |
| (g) | Actual TOC Removal Ratio | 1.18 |
| (h) | Reported TOC Removal Ratio | 1.18 |

II. Alternative Monitoring for SUVA

| | | |
|-----|-----------------------------|--|
| (a) | Date (mm/dd/yyyy) | |
| (b) | Source Water SUVA (L/mg-m) | |
| (c) | Treated Water SUVA (L/mg-m) | |

Additional Comments:

| | | | | | |
|------------------------------|--------------|-----------------------------------|------------|--------------|------------|
| Entered / Updated by: | Vernon Grant | Certification No. / Class: | 14707 / W1 | Date: | 03/08/2018 |
|------------------------------|--------------|-----------------------------------|------------|--------------|------------|