

September 4, 2018

TO: All Bidders under Request for Bid (RFQ) No. 18-300131

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. # 2

RFQ No. 18-300131 – Lou Walker Senior Center Resinous Flooring Installation. The following questions were submitted and received pertaining to this ITB; the County’s responses are as follows:

A. Question #1: What type of epoxy floor is currently on the floor now?

a. Answer: Key Resin

B. Question #2: Is the floor currently sloped (is the floor currently pitched)?

a. Answer: Yes, the floor is sloped in some areas but not in the toilet areas. The floor slopes need to be corrected to achieve positive slopes to the existing drains.

C. Question #3: Would the County be interested in a Key Resin substitute?

a. Answer: No. Key Resin is the manufacturer’s product which we are removing from the Lou Walker rest/locker rooms due to the poor installation.

D. Question #4: Can the RFQ be extended?

a. Yes. RFQ No. 18-300131 will be extended to **Friday, September 7, 2018; 3PM EST.**

E. Picture included. The below picture is a sample of flooring we are requesting:



- F.** It is the responsibility of each bidder to ensure all awareness of all addenda issued under this RFQ. Please sign and return this addendum. You may call Jovan Hooper, Procurement Agent at (404) 371 - 3644 before the bids are due to confirm the number of addenda issued.
- G.** All other conditions remain in full force and effect.



Jovan Hooper
Procurement Agent
Department of Purchasing and Contracting

Page 2

Request for Quote (RFQ) No. 18-300131 – Lou Walker Senior Center Resinous Flooring Installation

ACKNOWLEDGMENT

Date: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

(Signature)

(Title)