



November 1, 2021

TO: All Bidders under **RFQ 21-3003759 Gravity Filter Sand Installation at Pole Bridge (One-Time Buy)**

FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. 1

Request for Quotation RFQ 21-3003759 Gravity Filter Sand Installation at Pole Bridge (One-Time Buy), is hereby amended as follows:

- 1. Questions were received pertaining to this RFQ. The questions and the resulting responses are provided below:

1.	<p>Question: Will the sand be provided by the County or the contractor?</p> <p>Answer: Yes, the County will provide the sand.</p>
2.	<p>Question: What size is required for the sand?</p> <p>Answer: 1.4-1.6 mm effective, less than 1.5 UC, 6000 cubic ft needed</p>
3.	<p>Question: Does the sand need to be disinfected after installation?</p> <p>Answer: No.</p>
4.	<p>Question: Is there a fire hydrant close to the filters that we can access to slurry the sand into all the filters?</p> <p>Answer: Yes, the fire hydrant is located at the north west corner of the Filter building.</p>

- 2. It is the responsibility of each bidder to ensure that they are aware of all addenda issued under this RFQ. **Please sign and return this addendum.** You may email Sharice Feagins-Bailey at sfbailey@dekalbcountyga.gov before the quotes are due to confirm the number of addenda issued.
- 3. All other conditions remain in full force and effect.

Sharice Feagins-Bailey
 Procurement Technician
 Department of Purchasing and Contracting

ACKNOWLEDGMENT

Date: _____

The above Addendum #1 is hereby acknowledged:

(NAME OF BIDDER)

(Signature)

(Title)