



DEKALB COUNTY FIRE RESCUE DEPARTMENT



Darnell D. Fullum, Director/Fire Chief

Fire Marshal Division-Chief Joseph Cox, Fire Marshal

330 West Ponce De Leon Avenue, Decatur, Georgia 30030

Phone: 404-371-2776 Fax: 404-687-2430

<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED See fire notes* in attached packet, and on plan Sheet(s) _____ for details & locations	330 W. Ponce de Leon, Decatur, GA 30030 Phone: (404) 371-6209
<input type="checkbox"/> Please see attached copy of 2012 Int'l Fire Code Appendix D Fire Apparatus Access Roads for details referenced below.	

Provide information that is checked in the as indicated below:

I. MINIMUM ACCESS ROAD REQUIREMENTS

- (A.) Load Capacity.....75,000 lbs.* (Ref: IFC, D-102.1)
- (B.) Unobstructed Width.....20 ft. (from curb to curb)
For buildings less than 30 ft. in height; otherwise see IFC-D
- (C.) Clearance Height.....13'6" (Ref: IFC, 503.2.1)
- (D.) Turning Radii.....35 Ft. I.D. / 50 Ft. O.D. **
- (E.) Slope/Grade.....10% (maximum) **
- (F.) Building Perimeter Proximity.....See attached copy of I.F.C., Chap
Service Features, Sec 503.1 &
503.1.1"
- (G.) Aerial Apparatus Fire Roads
 - (A.) Where RequiredIFC, Sec D105.1
 - (B) Width.....IFC, Sec D105.2
 - (C) Proximity to Building.....IFC, Sec D105.3

II. FIRE HYDRANTS

- (A.) Hydrants must be on the property side of the roadway, within 400' 500'
 600' road travel distance from all grade level portions of the structures perimeter.
See IFC, Chap 5, Sec 503.2.5, and/or 508.5.1 (exception) and/or
IFC D Sec 103.1 and/or 508.5.1 (exception).
- (B.) Fire Hydrant Systems.....IFC, Sec. 508.5
- (C.) Inspection & Testing.....IFC, Sec. 508.5.2

- (D.) Private Fire Service Mains & Water Tanks.....IFC, Sec. 508.5.3
- (E.) Obstructions.....IFC, Sec. 508.5.4
- (F.) Clear Spaces Around Hydrants.....IFC, Sec. 508.5.5
- (G.) Physical ProtectionIFC, Sec. 508.5.6

- III. Gate Policy.....IFC, Sec D-103.5

- IV. Fire Service Water Mains.....NFPA 24, 2002 Ed.
- V. Building Address.....IFC, Sec. 505.1
- VI. Dead-End Fire Lanes.....IFC, Sec. D103.1
- VII. Dead-End Fire Apparatus Access Road Turnarounds.....IFC, Sec. D103.4
- VIII. Fire Lane Signs.....IFC, Sec. D103.6
- IX. Designated Barrier Free Parking.....GAC 120-3-20-.17
 - Quantity.....GAC 120-3-20-.17 (1) & OCGA Title 30-3-2 (10) (A)
 - Location.....GAC 120-3-20-.17 (2)
 - Signage.....GAC 120-3-20-.17 (4)
- X. Transformer Pad Location.....1999 GSFC Modif 5-1.8.3
- XI. Demolition Permits.....IFC, Chap 14/NFPA#241
- XII. Storage Tanks.....GSFC/DKFM Approval
- XIII. High-Piled Combustible Storage.....IFC, Chap. 23
- XIV. Fire Department Connections.....IFC, Chap 9/NFPA#24
- XV. Standpipes.....IFC, Sec 133/NFPA#14
- XVI. Grass Pavers.....DKFM Approval/Mfrs' Specifications
- XVII. Miscellaneous _____

* = Per 2003/2006 International Fire Code [IFC] as indicated within ().
 ** = Per DKCO. Fire & Rescue Services policy requirement

Please Note: The word "should" does not diminish the necessity of any of the above requirements.

FOR FIRE INSPECTION APPOINTMENT: PLEASE CALL 404/371-3010 FOR PERMITS ISSUED BY DEKALB COUNTY/AND OR MUNICIPALITIES. IF ADDITIONAL ASSISTANCE IS NEEDED PLEASE CALL 404/371-9256

Revision: ab: 5/29/13