

81010 BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=	97	23 - %	01/30 - Monthly	CA - CALCTD	
				Permit Req.	>=	85 MINIMUM				23 - %
				Value NODI						
81011 Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	99	23 - %	01/30 - Monthly	CA - CALCTD	
				Permit Req.	>=	85 MINIMUM				23 - %
				Value NODI						

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Corrected influent loadings for TSS and BOD. Due to error found, the effluent flow is used for influent loading. Influent flow recorded includes recycle streams. Correction of the influent flow issue is underway.

Attachments

Name	Type	Size
SFMOR_1072016.xls	xls	447488

Report Last Saved By

Dekalb County Department of Watershed Management

User: slglenn@dekalbcountyga.gov | Date/Time: 2016-08-18 18:51 (Time Zone: -04:00)
 Name: Sandra Glenn
 E-Mail: slglenn@dekalbcountyga.gov