

81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=	98			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85 MINIMUM			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	100			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85 MINIMUM			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Georgia NPDES permit sets specific detection limit for total chlorine at 0.05 Mg/L. Effluent Flow used for the influent BOD and TSS loadings until a true influent flow meter without returns can be installed.

Attachments

Name	Type	Size
CopyAugust2016.xlsx	xlsx	76792

Report Last Saved By

Dekalb County Department of Watershed Management

User: slglenn@dekalbcountyga.gov

Date/Time: 2016-09-14 11:36 (Time Zone: -04:00)

Name: Sandra Glenn

E-Mail: slglenn@dekalbcountyga.gov