

81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=	98			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85 MINIMUM			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	99.6			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85 MINIMUM			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Composite samples were collected from 6 am to 6 am instead of on a calendar day. This is being corrected. Influent meters are in the process of being installed. Until installed, effluent data is being used for influent. High flow and concentrations at the latter end of the month impacted monthly averages but not the weekly as the days with high flow and loading will impact the first week of next months reports.

Attachments

Name	Type	Size
SFSMRNov2016SLG.xls	xls	342016

Report Last Saved By

Dekalb County Department of Watershed Management

User: sglenn@dekalbcountyga.gov
 Name: Sandra Glenn
 E-Mail: sglenn@dekalbcountyga.gov

Date/Time: 2016-12-15 11:31 (Time Zone: -05:00)