

81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=	96			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85 MINIMUM			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	99			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85 MINIMUM			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

GA NPDES permit specific detection limit for TRC is 0.05 Mg/L. Effluent flows used for calculations until a new influent flow meter can be installed. Effluent flows are used for influent BOD and TSS loadings.

Attachments

Name	Type	Size
September2016DMR.xlsx	xlsx	99694

Report Last Saved By

Dekalb County Department of Watershed Management

User: sglenn@dekalbcountyga.gov

Name: Sandra Glenn

E-Mail: sglenn@dekalbcountyga.gov

Date/Time:

2016-10-13 19:31 (Time Zone: -04:00)